

October 6, 2025

**Subject: RFQ # 26035-A Redwine Road Handrail Installation
Addendum #1**

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced **RFQ**. You will need to consider this information when preparing your quote.

1. The bid item for the handrail on the pricing sheet and in the scope of work is 360 LF, however the plan sheet for the wall on RW3 shows the wall at station 0+00 to station 3+06 which is 306 LF could they please clarify?
The pricing sheet has been updated to reflect the correct length of 306 LF(Attachment 1).
2. The bid item for the concrete between wall and curb shows 26 ft. however in the field it is about 46 ft. +/-, could they please clarify?
The pay item for Class B concrete has been updated to reflect a length of approximately 47 LF.
3. The footings for the handrail are 12" x 18" per detail on sheet RW4 which seem big for this application of 36" high pipe handrail, the holes between the wall and header curb can't be that large. Could they verify that the footings need to be that large?
An minimum 8-IN wide by 18-IN deep footing will be acceptable.
4. The cart path will have to be closed while the work is being done, is that a problem? We would rather close the path and not the road.
On days when school is in session, path closure is limited to the hours between 9:00am and 2:00pm. At least one 5-ft lane of path must remain open for use outside of the listed hours. On days when school is not in session, path closure is permitted during the working hours from 8:00am to 5:00pm. No road closures or lane restrictions are allowed for Redwine Road or Bernhard Road.

Received by (Name): _____ Company _____

Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this RFQ has not changed. **The opening time and date are 3:00p.m., Wednesday, October 8, 2025.** Quotes must be received by the Purchasing Department at the address above, Suite 204, at or before the opening date and time.

The deadline for inquiries has passed, so the Purchasing Department will not be able to accept any additional questions after this time.

If you have questions, please contact Sherry White, Senior Contract Administrator at (770) 305-5314, fax (770) 719-5544 or email at swhite@fayettecountyga.gov.

Sincerely,



Ted L. Burgess
Chief Procurement Officer

PRICING SHEET

RFQ #26035-A: Redwine Road Handrail Installation

Responder agrees to perform all the work described in the Contract documents for the following prices:

PAY ITEM NO.	ITEM DESCRIPTION	ESTIMATED QUANTITY	UNIT	UNIT PRICE	EXTENDED AMOUNT
500-3200	CLASS B CONCRETE (FOR APPROXIMATELY 47 LF BETWEEN HEADER CURB AND RETAINING WALL)	1.80	CY		
515-2020	GALV STEEL PIPE HANDRAIL, 2 IN, ROUND	306.00	LF		
TOTAL QUOTED AMOUNT					

NOTES:

1. All applicable charges shall be included in your total quoted amount, including but not limited to materials, equipment, installation, labor, and any other amounts. No additional charges will be allowed after the quote received by date.
2. All warranties shall be included in your total quoted amount.

State time needed to commence work after notice to proceed is issued _____ Days.

State length of time needed to complete project _____ Days.

State, List or Attach the terms of your warranty, if applicable: _____

COMPANY'S NAME: _____