

October 7, 2025

**Subject: RFQ # 26035-A Redwine Road Handrail Installation
Addendum #2**

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced **RFQ**. You will need to consider this information when preparing your quote.

1. On photo #1 Exhibit A: You want us to remove a section of sod located between the header curb and retaining wall. What do you want us to replace the sod with?
Per Scope and Specification Item #2 in the RFQ; "Remove section of sod between header curb and retaining wall (shown in photo 1 of Exhibit A) and prepare ground to form and pour approximately one cubic yard of Class B Concrete with a minimum thickness of four inches. Concrete shall be level and uniformly sloped in relation to header curb and retaining wall. Isolation joint shall be required between retaining wall and concrete".
2. We have reviewed the new pricing sheet and have a comment and question. The instructions for the area between the wall and the header curb are to install concrete 4" minimum x 12" wide by 47 ft long. This is about .58 cubic yard. Is that line item just material, or material and labor to install that strip between the wall and curb. Can you clarify what is to be in that line item or just remove and make the concrete strip part of the handrail with footings price and not separate them. It is just what is required for that approximate 47 ft.
Payment is full compensation for incidentals, and direct and indirect costs, to complete the Work. Pay Item 500-3200 is for the concrete area between the header curb and retaining wall only and will be paid for at the Contract Price per cubic yard complete in place and accepted, and will be measured in the field and verified with material tickets. The concrete for the handrail footings shall be included in the handrail pay item 515-2020.

Received by (Name): _____ Company _____


Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this RFQ has not changed. **The opening time and date are 3:00p.m., Wednesday, October 8, 2025.** Quotes must be received by the Purchasing Department at the address above, Suite 204, at or before the opening date and time.

The deadline for inquiries has passed, so the Purchasing Department will not be able to accept any additional questions after this time.

If you have questions, please contact Sherry White, Senior Contract Administrator at (770) 305-5314, fax (770) 719-5544 or email at swhite@fayettecountyga.gov.

Sincerely,



Ted L. Burgess
Chief Procurement Officer