

October 12, 2026

**Subject: ITB #27038-B: Greenfield Circle (250) Culvert Replacement
Addendum #1**

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced ITB. You will need to consider this information when preparing your bid.

1. Regarding the option to use a precast box culvert, the specifications state that:
"Payment for Precast Reinforced Concrete Box Culvert Barrel Sections and End Sections will be based on the cast-in-place alternate and will include CONVERSIONS when using the precast design." Could you please clarify what is meant by "CONVERSIONS" in this context?

"CONVERSIONS" refers to converting the installed precast box culvert into equivalent concrete (CY) and reinforcing steel (LB) quantities based on the cast-in-place design, in accordance with GDOT Section 513.4.

2. Would the conversion simply be based on the quantity of concrete (CY) required for the precast box culvert multiplied by the cast-in-place concrete unit price (\$/CY)? If so, it would result in a lower payable quantity when using precast construction in lieu of the cast-in-place alternate.

No. Payment will be based on the equivalent cast-in-place design quantities, not the actual concrete quantity used in the precast culvert. Using precast construction will not reduce the payable quantities solely because less material is required, in accordance with GDOT Sections 513.4 and 513.5.

Received by (Name): _____ Company _____


Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this ITB has not changed. **The opening time and date are 3:00p.m., Friday, October 16, 2026.** Bids must be received by the Purchasing Department at the address above, Suite 204, at or before the opening date and time.

The deadline for inquiries has passed, so the Purchasing Department will not be able to accept any additional questions after this time.

If you have questions, please contact Sherry White, Senior Contract Administrator at (770) 305-5314 or email at swhite@fayettecountyga.gov.

Sincerely,

A handwritten signature in blue ink, appearing to read "Ted L. Burgess", enclosed within a blue oval shape.

Ted L. Burgess
Chief Procurement Officer