

August 15, 2025

**Subject: ITB #26016-B Mark Lane Culvert Replacement
Addendum #1**

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced **RFQ**. You will need to consider this information when preparing your quote.

1. **We are interested in bidding on the two box culvert projects that the county has out for bid; however, the ITB's require the Prime Contractor SHALL be GDOT prequalified in Work Class 500 Concrete Structures (Bridge & Culverts) or 513 (Precast Reinforced Concrete Box Culvert Brl & End Sect. Would the county consider additional prequalified GDOT work class codes of 550 and 668 to perform this work since the structure is precast and not poured in place?** The scope and complexity of this project involves critical structural components, environmental constraints, and installation challenges that go beyond standard precast placement. The work class requirement ensures bidders have documented experience and proven capability in delivering projects of similar size, scope, complexity, and structural significance. Work classes 500 and 513 are specific to concrete structures and reinforced concrete box culverts. Only the work classes expressly listed in the solicitation will be accepted for this procurement.
2. **It appears that the Contractor is directed to install a 6x6 tee between the sleeve and proposed 6-inch gate valve for the temporary bypass. At the end of the project, will the Contractor install a plug on the face of the 6x6 tee?** The 6x6 tees used for the temporary bypass shall be removed when the final tie-in is made.
3. **Is the alignment of the 6-inch temporary bypass line up to the Contractor's discretion?** The placement and alignment of the temporary bypass is at the contractor's discretion as long as the detail is followed.

Received by (Name): _____ Company _____

Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this RFQ has not changed. **The opening time and date are 3:00p.m., Tuesday, August 26, 2025.** Quotes must be received by the Purchasing Department at the address above, Suite 204, at or before the opening date and time.

Questions regarding this solicitation will be accepted until 3:00p.m., Wednesday, August 20, 2025. After that, we will not be able to respond to any inquiries about this project.

If you have questions, please contact Sherry White, Senior Contract Administrator at (770) 305-5314, fax (770) 719-5544 or email at swhite@fayettecountyga.gov.

Sincerely,

A handwritten signature in blue ink that reads "Sherry White for Ted Burgess". The signature is written in a cursive, flowing style.

Ted L. Burgess
Chief Procurement Officer