

April 28, 2026

**Subject: RFQ 26131-A: Fire Hydrant Replacement Services (7)
Addendum #1**

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced **RFQ**. You will need to consider this information when preparing your quote.

1. **Do all the hydrants that need to be replaced have up and showing isolation valves?**
This is currently unknown. Vendors are free to visit all fire hydrants.

2. **What is the standard bury depth of the hydrants that the county requires? Reason for asking bury depth is cost could go up or down depending on bury depth required by county standards.**
All depths are given in the Standards and Specifications provided in the RFQ.

3. **Is the valve box concrete collar size/ shape? There is a square 2ft by 2ft or round 1ft by 1ft.**
IN STANDARDS AND SPECIFICATION PROVIDED – 1.2.4 All boxes not located in the roadway shall have a 24 in. diameter pre-cast concrete collar placed level around the top for protection.

4. **Is a bid bond required for this project?**
No.

Received by (Name): _____ Company _____

Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this RFQ has changed. The opening time and date are **3:00p.m., Tuesday, May 5, 2026**. Quotes must be received by the Purchasing Department at the address above, Suite 204, at or before the opening date and time. Please advise that quotes can be emailed as well.

The deadline for inquiries has passed, so the Purchasing Department will not be able to accept any additional questions after this time.

Questions regarding this solicitation will be accepted until Tuesday, April 21, 2026. After that, we will not be able to respond to any inquiries about this project.

For administrative matters or questions about the procurement process, please contact Colette Cobb, Contract Administrator at (770) 305-5115 or email at ccobb@fayettecountyga.gov.

Sincerely,

A handwritten signature in blue ink, appearing to read "Ted L. Burgess", enclosed within a large, loopy blue oval.

Ted L. Burgess
Chief Procurement Officer