

August 25, 2026

**Subject: RFQ #27022-A: Starrs Mill Educational Facility Building Modifications
Addendum #2**

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced RFQ. You will need to consider this information when preparing your quote.

1. Will the ceiling need to be insulated?

Yes. Provide and install R-38 blown-in insulation above the wood-framed drywall ceiling. Include all labor, materials, equipment, and associated costs required for the insulation in Line Item 4 – Ceiling Replacement & Attic Access. Include adjustment, relocation, and/or securing of existing wiring within the attic space as necessary to accommodate installation.

Received by (Name): _____ Company _____

Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this RFQ has not changed. **The opening time and date are Quotes will be accepted until 3:00pm on Friday, August 28, 2026.** Quotes must be received by the Purchasing Department at the address above, Suite 204, at or before the opening date and time.

The deadline for inquiries has passed, so the Purchasing Department will not be able to accept any additional questions after this time.

If you have questions, please contact Sherry White, Senior Contract Administrator at (770) 305-5314 or email at swhite@fayettecountyga.gov.

Sincerely,



Ted L. Burgess
Chief Procurement Officer