

October 13, 2026

**Subject: RFQ 27047-A: Kiwanis Park Barrier Netting
Addendum #2**

Gentlemen/Ladies:

Below, please find responses to questions, clarifications, and additional information for the above-referenced Request for Quote. This information shall be considered when preparing your quote.

- 1. Please clarify the scope of the required stamped engineered drawings and structural calculations. Are the engineered documents required to address the entire existing barrier-netting system at Fields #5 and #6, including existing poles and structures that are not being replaced, or only the new and replacement components included in the contractor's scope of work and their connection to the existing system?**

All connections and attachments to existing poles and structures shall comply with the manufacturer's installation instructions and specifications. Where the manufacturer's installation requirements cannot be met, engineered attachment details or replacement of the affected existing components shall be required to demonstrate structural adequacy and code compliance.

The engineered design shall address the new structural components. Existing poles and structures not being replaced or modified are not required to be independently engineered, provided the proposed installation complies with the manufacturer's requirements and does not exceed the structural capacity of the existing components.

For clarification, the term "complete barrier-netting system" used in Addendum #1 does not require existing poles and structures that are not being replaced or modified to be independently engineered, provided the proposed installation complies with the manufacturer's requirements and does not exceed the structural capacity of the existing components.

Received by (Name): _____ Company _____


Note: If this addendum is not returned to the Fayette County Purchasing Department, or if it is returned unsigned, responding individuals, companies, or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The due date for this RFQ **remains unchanged**. Quotes will be accepted until **3:00 p.m. on Tuesday, October 20, 2026**. Quotes must be received via email to Tamia Carnell, Buyer & Contract Coordinator, at tcarnell@fayettecountyga.gov or via fax to (770) 719-5534 at or before the due date.

The deadline for inquiries has passed. No additional questions regarding this solicitation will be accepted.

For administrative matters or questions about the procurement process, please contact Tamia Carnell, Buyer & Contract Coordinator at (770) 305-5150 or email at tcarnell@fayettecountyga.gov.

Sincerely,



Ted L. Burgess
Director of Purchasing