

October 23, 2026

**Subject: RFQ 27050-A: Kiwanis Park Field #7 Fencing, Dugout & Backstop
Addendum #1**

Gentlemen/Ladies:

Below, please find responses to questions, clarifications, and additional information for the above-referenced Request for Quote. This information shall be considered when preparing your quote.

- 1. Permits: Does this project require a permit? If so, approximately how long is the permit review/issuance process?**
The RFQ currently states that the contractor is responsible for obtaining all necessary permits. The process can range from 1 day to several days depending on if all the paperwork has been submitted.
- 2. Grounding rods: Are grounding rods required for the new fencing/backstop? If so, please specify the required quantity, spacing, and/or locations.**
The specifications state that grounding rods must be positioned so they are not hazardous to players or spectators, but do not specify how many are required or how frequently they should be installed. Please refer to ASTM guidelines.
- 3. Backstop middle rails: Please confirm the required rail configuration for the backstop. Is one middle rail required along the entire length of the backstop or are additional middle rails required elsewhere?**
Middle rails should be spaced evenly every 5' starting at the bottom rail.
- 4. Yellow outfield top rail: If the specified yellow pipe cannot be sourced, would the County allow the contractor to use the specified pipe and have it powder coated yellow, or is factory-finished yellow pipe required?**
The specifications currently require yellow Master Color "LCX" LG-40 pipe for the outfield top rail. Powder coated yellow is permissible.
- 5. Irrigation: Are there known irrigation lines within the project area?**
The RFQ states that Building & Grounds Maintenance will locate the irrigation lines prior to work.
- 6. Equipment on the field: Will we be permitted to drive a skid steer or similar construction equipment onto the playing field? If so, are there any access, ground-protection, or restoration requirements?**
Equipment is permissible on the field as long as ground protection is utilized when appropriate. Please note, the specifications state the successful contractor is responsible for all damage done by crew, which includes but not limited to damages to sod, irrigation systems, electrical wiring, signs, structures, concrete, asphalt, or any other county equipment or property improvement.
- 7. Dugout replacement: Do we have to remove and replace the dugout fencing and roof materials?**

The current scope states that all dugout roof materials and fencing are to be removed and replaced on both the first-base and third-base sides.

8. **New post installation:** Are we required to excavate/drill new post holes and install new concrete footings?

Yes.

9. **Could you please confirm the following for the fence section extending from the corner of the back stop toward the outfield corner near the parking lot? Fence height: Should this section be 30 feet high? Overhead clearance: Is the required overhead clearance 6 feet above the fence?**

The RFQ states to install backstop 30-foot tall with a 6-foot overhang running from dugout side closest to home plate to dugout side closest to home plate. Also install 30-foot-tall section without the overhang from in front of dugout to the end of the bleacher cover area. This fencing should be the same on both the 1st base as well as the 3rd base side of the field.

Additional Change to the Specifications:

Two additional single gates shall be installed leading to the field, one at the end of the bleacher area closest to the outfield grass on the first-base side and one at the corresponding location on the third-base side of the field.

The additional gates shall comply with the single-swing gate specifications contained in the RFQ and shall be appropriately boxed into the fencing with the necessary top and side railing to support each gate.

Received by (Name): _____ Company _____

Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The due date for this RFQ has been extended. Quotes will now be accepted until 12:00 p.m. on Monday, November 2, 2026. Quotes must be received via email to Tamia Carnell, Buyer & Contract Coordinator, at tcarnell@fayettecountyga.gov or via fax to [\(770\) 719-5534](tel:770-719-5534) at or before the due date.

The deadline for inquiries has passed, so the Purchasing Department will not be able to accept any additional questions after this time.

For administrative matters or questions about the procurement process, please contact Tamia Carnell, Buyer & Contract Coordinator at (770) 305-5150 or email at tcarnell@fayettecountyga.gov.

Sincerely,



Ted L. Burgess
Director of Purchasing