

August 22, 2025

**Subject: ITB #26015-B Darren Drive
Addendum #1**

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced **RFQ**. You will need to consider this information when preparing you bid.

1. What is the plan to keep traffic open for the houses? See Project Specific Terms & Conditions Section W, Traffic Control Notes on Sheet C-002, Demolition Note A.7 on Sheet CD-101, General Sheet Note 12 on Sheet CS-101, and General Sheet Note 1 on Sheet CG-101.
2. What is the engineer's budget? The County does not provide budget information for bidding purposes. We ask that all bidders submit proposals based on their most competitive pricing and a clear understanding of the scope of work as outlined in the ITB documents.
3. Is there a laydown area the contractor can use? See plan Sheet CD-101.
4. When will NTP be expected? A specific NTP date has not been determined. The issuance of the NTP will depend on the timeline for receiving and processing all required documentation through the Purchasing Department. The County is currently aiming for an anticipated NTP in October 2025. Please note that this timeframe is subject to change based on the completion of the necessary procurement steps.
5. If the contractor chooses to place a precast culvert, how will the precast box culvert be paid? The project terms state that the precast will be paid under an alternate, but I don't see an alternate on the bid form. Refer to GDOT Specification 513. Payment for Precast Reinforced Concrete Box Culvert Barrel Sections and End Sections will be based on the cast-in place alternate and will include conversions when using the precast design. Cast-in-place concrete will be paid for under Section 500 and reinforcing steel will be paid for under Section 511.
6. The drawings do not show an apron on the inlet or outlet of the culvert. Will any aprons be required? No, aprons are not required for this project.

Received by (Name): _____ Company _____


Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this ITB has not changed. **The opening time and date are 3:00p.m., Tuesday, August 26, 2025.** Bids must be received by the Purchasing Department at the address above, Suite 204, at or before the opening date and time.

The deadline for inquiries has passed, so the Purchasing Department will not be able to accept any additional questions after this time.

If you have questions, please contact Sherry White, Senior Contract Administrator at (770) 305-5314, fax (770) 719-5544 or email at swhite@fayettecountyga.gov.

Sincerely,



Ted L. Burgess
Chief Procurement Officer