



**Purchasing Department**  
140 Stonewall Avenue West, Ste 204  
Fayetteville, GA 30214  
Phone: 770-305-5420  
[www.fayettecountygagov](http://www.fayettecountygagov)

January 13, 2026

**Subject: RFQ #26088-A Traffic Signal Battery Backup  
Addendum #1**

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced **RFQ**. You will need to consider this information when preparing your quote.

1. The questions due date has been moved to 12:00p.m., Wednesday, January 14, 2026.
2. The due date for the quotes has been changed to 3:00p.m., Tuesday, January 20, 2026.
3. I would like to point out an issue that I have had with the multilink 10-502-10 power transfer switch you have in the RFQ. This switch does not accommodate the size Awg #6 Traffic signal power supply conductor. The correct power transfer switch is the multilink 10-505-20. The 101-502-10 is a Multilink Manual Transfer Switch (you have to be present to swap it over to inverter) and the 10-505-20 is the Multilink Safety Auto Transfer Switch, which goes into inverter mode (batteries) and back out of inverter mode with no one present to physically do it.

**Please see the attached updated Price Sheet.**

4. Question—do you have a 2200 W UPS going in the cabinet? Maybe an EP-2200 or EP-2200T?

The Road Department doesn't believe the existing system has an existing surge protection system that can be used with the new system. So if the new battery back-up system requires a surge system, please include it in the battery system line item on the Price Sheet.

Received by (Name): \_\_\_\_\_ Company \_\_\_\_\_


Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this RFQ has changed. **The opening time and date are 3:00p.m., Tuesday, January 20, 2026.** Quotes must be received by the Purchasing Department at the address above, Suite 204, at or before the opening date and time.

The deadline for inquiries has been moved to 12:00p.m., Wednesday, January 14, 2026.

If you have questions, please contact Sherry White, Senior Contract Administrator at (770) 305-5314, fax (770) 719-5544 or email at [swhite@fayettecountyga.gov](mailto:swhite@fayettecountyga.gov) .

Sincerely,

A handwritten signature in blue ink, appearing to read "Ted L. Burgess". The signature is fluid and cursive, with a large, stylized "T" and "B".

Ted L. Burgess  
Chief Procurement Officer

**PRICING SHEET**  
**RFQ #26088-A: Traffic Signal Battery Backup**

Responder agrees to perform all the work described in the Contract documents for the following prices:

ITEM	QUANTITY	UNIT OF MEASURE	UNIT PRICE	EXTENDED PRICE
Labor	1	Lump Sum		
Traffic Control	1	Lump Sum		
Battery System 10-502-10	1	Each		
Battery for Signal	4	Each		
TOTAL BASE PRICE				
Alternate:				
Increase in base quoted price to upgrade to multilink 10-505-20. Include all increased costs, including labor, traffic control, or other additional cost.				

**NOTES:**

1. All applicable charges shall be included in your total quoted amount, including but not limited to materials, equipment, labor, and any other amounts. No additional charges will be allowed after the quote "received by" date.
2. Award of contract will be Base Quote only or Base Quote plus alternate, at the sole discretion of the County.

State time needed to commence work after notice to proceed is issued \_\_\_\_\_ Days.

State length of time needed to complete project \_\_\_\_\_ Days.

State the Proposed Battery System and Warranty: \_\_\_\_\_

COMPANY'S NAME: \_\_\_\_\_