



**Department of Building
Safety**

Suite 201

Phone: 770-305-5403 Fax: 770-305-5212

Web: http://www.fayettecountyga.gov/bldg_permits/infobldg.asp

NOTICE TO INDUSTRY

**APPROVED FOR
PUBLIC DISTRIBUTION**

Notice to Industry No.: 2017-6-19

Discipline: T-Pole

Date Created: 06/19/17

Date Effective: 07/01/17

SUBJECT: T-POLE INSTALLATION

Details: Effective 7/1/17 the following changes shall be enforced concerning the installation and inspection of t-poles:

T-poles must be installed and the ground rod driven to be approved by our Inspectors. The meter base shall be free of debris/paint/etc. and shall have 2 GFCI protected outlets. The ground rod shall be driven and the acorn clamp securely tightened.

We will no longer allow t-poles lying on the ground to be approved.

Should you have any questions, please contact me at 770-305-5130.

Sincerely,

Joe Scarborough
Building Official/Director
Fayette County Department of Building Safety

