



# Fayette COUNTY

"WHERE QUALITY  
IS A LIFESTYLE"

## PURCHASING DEPARTMENT

140 STONEWALL AVENUE WEST, STE 204  
FAYETTEVILLE, GEORGIA 30214  
PHONE: 770-305-5420  
www.fayettecountyga.gov

March 23, 2017

### Subject: IFB #1206-B: Lee's Mill Culvert Replacement – Addendum #3

Gentlemen/Ladies:

Included herein is additional information and clarification for the above referenced invitation for bids. Please consider all of this information when preparing your bid.

**Could you provide more detail on the type of guardrail and end treatment required?** "The guardrails for the project shall be a "W" Beam Type and have a Type 12B terminal for the approach and Type 1 anchor for the trailing end in each travel direction. Contractor shall refer to GDOT details numbers 4380 for "W" beam type, 4383 for the Type 1 anchor, and 4384 for the Type 12B terminal for additional information."

Received by \_\_\_\_\_ Company \_\_\_\_\_

Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, all responders shall still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this invitation for bids has not changed. **The opening date is: 3:00 p.m., Wednesday, March 29, 2017.** Bids must be received in the Purchasing Department at the address above in Suite 204 on or before the opening date and time.

If you have already submitted a bid, it will be opened and read on the opening date. If you would not like your bid opened or should you desire to submit a new bid, you must notify Trina Barwicks, Contract Administrator in writing by email: [tbarwicks@fayettecountyga.gov](mailto:tbarwicks@fayettecountyga.gov) or fax to (770) 719-5515, your desire to not have your bid opened.

Thank you for your attention to this matter.

Sincerely,

Ted L. Burgess  
Director of Purchasing