



Fayette COUNTY

"WHERE QUALITY
IS A LIFESTYLE"

PURCHASING DEPARTMENT

140 STONEWALL AVENUE WEST, STE 204
FAYETTEVILLE, GEORGIA 30214
PHONE: 770-305-5420
www.fayettecountyga.gov

May 16, 2017

Subject: IFB #1318-B: Water Distribution Parts Annual Contract – Addendum #1

Gentlemen/Ladies:

Included herein is additional information and clarification for the above referenced Invitation for Bids. Please consider all of this information when preparing your Bid.

- 1. Will you provide specifications for the meters line items 1 and 2?**
Meters should be AWWA approved, with registers compatible with Badger Meter Orion transmitter with data profiling RTR and/or HRE.
- 2. Will you provide clarification for Items 149-158; ex. are 150 lb. flange kits with gaskets, bolts and nuts to be provided? If so, what length of bolts are required?**
Yes, 150lb. Grade 2 bolts with nuts of varying lengths appropriate for the diameter size of the Set/Kit.

Received by _____ Company _____

Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, all responders shall still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this Invitation for Bids has not changed. **The opening date is: 3:00pm, Thursday, May 25, 2017.** Bids must be received in the Purchasing Department at the address above in Suite 204 on or before the opening date and time.

If you have already submitted a Bid, it will be opened and read on the opening date. If you would not like your Bid opened or should you desire to submit a new Bid, your original Bid must be picked up, or you must notify the Fayette County Purchasing Department **in writing** to, email address: tbarwicks@fayettecountyga.gov or fax to (770) 719-5515 of your desire to not have your Bid opened.

Thank you for your attention to this matter.

Sincerely,

Ted L. Burgess
Director of Purchasing