

September 12, 2019

**Subject: RFP #1670-P: Engineer of Record for Water System Interconnectivity Initiative
Addendum #3**

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced Request for Proposal. You will need to consider this information when preparing your proposal.

1. **Does the county have the previous safe-yield analyses? Will they be made available?**
Yes, and they will be made available once the project is awarded.
2. **Task 1C (Water Model Development), Item 4 says to establish scenarios including Base EP Chlorine Residuals. Are we to provide chlorine sample information?**
Water Quality modeling will not be performed in the scope of the project.
3. **Will responders be allowed to add hourly rates on the pricing schedule?**
Yes. As stated in the RFP, Section #8 (Fees & Hourly Rate Schedule) in Proposal Response requirements, include any job classifications that are not listed. You may attach additional sheets as necessary.
4. **Will the map on the Water System page be updated or will updated maps be provided by web-link?**
The map on the Water System web page will not be updated at this time. An overview map of the major water lines in the distribution system will be available for review in the Purchasing Department.
5. **The rate study includes a wholesale rate to the neighboring County and rates for Water System residential, commercial, and industrial customers (see Phase I and Phase II of Task 4 – Rate Study).**
6. **The water model shall be developed with Bentley WaterGEMS CONNECT or Innovyze InfoWater water distribution software.**
7. **Does Fayette County have Wells?**
Fayette County no longer uses wells and they are no longer included in our Permit to Operate.

Received by (Name): _____ Company _____


Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this RFP has changed. **The opening time and date are 3pm, Thursday, October 3, 2019.** Proposals must be received by the Purchasing Department at the address above, Suite 204, at or before the opening date and time.

The deadline for inquiries has been extended. The new deadline is 2pm on Thursday, September 19, 2019. All inquiries must be received by the deadline. After that we will not be able to respond to any inquiries about this project.

If you have questions, please contact Natasha Duggan, Contract Administrator at (770) 305-5150 fax (770) 719-5534 or email at nduggan@fayettecountyga.gov.

Sincerely,

A handwritten signature in blue ink, appearing to read "Ted L. Burgess", is written over a circular blue stamp or seal.

Ted L. Burgess
Director of Purchasing