

August 30, 2019

Subject: IFB #1714-B: Resurface McDonough and Ramah Road-Addendum 2

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced Invitation for Bid. You will need to consider this information when preparing your proposal.

1. It appears that there are two traffic loops on Ramah Road. If they are within the construction limits, will Fayette County be responsible for their replacement?

The proposed construction limits for this project will be just before the traffic loops. We will tie into the existing pavement before the existing traffic loops and not the existing pavement joint to prevent damage to these existing loops.

2. Will Fayette County handle any manhole or water valve adjustments that may be required?

We are not aware of any manholes or valves located within in this project limit, but Fayette County will handle any adjustments if needed.

3. On McDonough Road, how does the county want to address the shoulder building where there is an open ditch adjacent to the pavement without encroaching on the existing ditchline?

Contractor shall build a shoulder along the existing pavement where possible, with the exception of a lack of shoulder due to pipe crossing.

4. Will Silt Fence or hay bales be required on shoulder widening?

This will not be required by Fayette County.

Received by _____ Company _____

Note: Please sign and return this addendum with your submitted quote. Any responder not returning a signed addendum will still be responsible for compliance with any requirements, specifications, or changes contained in the addendum.

The time allowed for questions has expired. The received by date for this Invitation to Bid has not been changed. **Bids will be accepted until 3:00pm, Thursday, September 5, 2019.**

Thank you for your attention to this matter.

Sincerely,



Ted L. Burgess
Director of Purchasing

TLB/tc