

September 11, 2020

**Subject: ITB #1844-B: Redwine Road & Starrs Mill School Complex Multi-Use Path
Addendum #2**

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced Invitation to Bid. You will need to consider this information when preparing your bid.

- 1. The plans and pay items call for remove and reset fence (existing 3-rail PVC fence 593 LF) and 524 LF of Fence Special Design. The spec book gives the 3-Rail PVC and a 2-Rail wood fence. Which is the special design?**

The 524 feet of special design fence is the total of both fence types that are to be installed: 3-rail PVC and 2-rail wood. There are 434 ft. of new 3-rail PVC and 90 ft. of new 2-rail wood.

All the reset fence (593 LF) is 3-rail PVC fencing.

The total linear feet of the new and reset fence does not exactly match the removed fence quantity due to minor changes associated with the new fence alignment.

Received by (Name): _____ Company _____

Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this ITB has not changed. **The opening time and date are 3:00 p.m., Wednesday, September 16, 2020.** Bids must be received by the Purchasing Department at the address above, Suite 204, at or before the opening date and time.

The deadline for inquiries has passed, so the Purchasing Department will not be able to accept any additional questions after this time.

If you have questions, please contact Natasha Duggan, Contract Administrator at (770) 305-5150 fax (770) 719-5534 or email at nduggan@fayettecountyga.gov.

Sincerely,



Ted L. Burgess
Director of Purchasing