

November 5, 2020

**Subject: RFQ #1885-B: Brockton Court Culvert Replacement
Addendum #3**

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced Invitation to Bid. You will need to consider this information when preparing your bid.

- 1. Drawing C-102 says fence to be replaced by others. C-103 Says remove and replace. Is this fence to be replaced by the contractor or disposed of?**

Note to replace on Sheet C-103 is an error. It is the contractor's responsibility to only remove the portion of fence shown on sheet C-102. Fence is to be replaced by others.

- 2. For the Alt Bid 1 and the Alt Bid 2: Should the bid item #8 be removed from the base bid and replaced with Item A and B respectively. Or are items A and B Additional to the base bid.**

For the Alternate Bid Items A & B, please provide the **additional** amount it will cost to include either Stamped Concrete or Cast-in-Place Concrete. The Bid Tab has been revised and is attached to provide a more clear response. Please use the updated Bid Tab when submitting a bid.

- 3. For the Mill and Repave portion, please specify the depth of Milling.**

Fayette County Typical Road Section (Detail 5 on Sheet C-503) requires the topping for local roads to be 1.5" of 9.5MM. If damage caused to the roadway during construction extends beyond the 1.5" milling depth and topping thickness, the Contractor will be required to repair the roadway to an agreed upon depth per Fayette County Typical Road Section on Sheet C-503 and the Site. Paving Legend shown on Sheet C-103.

Received by (Name): _____ Company _____


Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The bid due date for this ITB has not changed. **The bid due time and date are 12:00 p.m., Tuesday, November 17, 2020.** Bids must be received by the Purchasing Department at the address above, Suite 204, at or before 12:00 p.m., Tuesday, November 17, 2020. A virtual bid opening will be held at 2:00 p.m. that day.

Questions regarding this solicitation will be accepted until 3:00 p.m., Wednesday, November 4, 2020. After that, we will not be able to respond to any inquiries about this project.

If you have questions, please contact Natasha Duggan, Contract Administrator at (770) 305-5150 fax (770) 719-5534 or email at nduggan@fayettecountyga.gov.

Sincerely,



Ted L. Burgess
Director of Purchasing

5. LUMP SUM BASE BID

Item No.	Description	Estimated Quantity	Unit	Total Price
1	Mobilization	1.00	LS	
2	Traffic Control	1.00	LS	
3	Erosion Control	1.00	LS	
4	Utility Relocation	1.00	LS	
5	Clearing & Grubbing	1.00	LS	
6	Excavation / Demolition	1.00	LS	
7	Culvert Construction	1.00	LS	
8	Redi-Rock Retaining Wall	1.00	LS	
9	Roadway Construction	1.00	LS	
10	Concrete Work	1.00	LS	
11	Construction Materials Testing & Inspections Allowance	1.00	LS	\$35,000.00
Brockton Court Culvert Replacement Total Lump Sum Base Bid (Items 1 through 11)				

ALTERNATE BID ITEMS

Item No.	Description	Estimated Quantity	Unit	Total Price
A	Additional Amount to include Stamped Concrete Retaining Wall in lieu of Redi-Rock Retaining Wall	1.00	LS	
B	Additional Amount to include Cast-in-Place Concrete Retaining Wall in lieu of Redi-Rock Retaining Wall	1.00	LS	