

April 30, 2021

**Subject: Invitation to Bid #1964-B: Roadway Striping
Addendum #1**

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced #1964-B Roadway Striping. You will need to consider this information when preparing your bid.

- 1. The proposal states that GADOT spec 652 and 653 shall be used but does not specify if paint is to be used for all long line striping, thermoplastic for all markings, or some combination of the two. If some combination of paint/thermo is to be used for long line striping, can you please provide a listing of which road will receive what material?** This project will follow 653 Thermoplastic. Please disregard 652 and paint on this project.
- 2. Are existing RPM's to be removed prior to installation of new RPM's?** No just replace missing RPM's.
- 3. Will the county clip, blade and clean the edges of the roadway prior to installation of edgelines?** Yes the County will be responsible for clipping and cleaning the edge of the roadway.
- 4. What kind of material will be required on each Road (Regular Paint, High Build Paint, or Thermoplastic striping)?** All work will be in Thermoplastic striping.
- 5. Will all stop bars, crosswalks, turn arrows, and hatching be restriped in thermoplastic?** Yes looking for all existing items to be redone in Thermoplastic.
- 6. Will there be any time restraints to install pavement markings?** No time restraints associated with this project.
- 7. What is the time line to finish project?** Work needs to be completed within 60 calendar days of NTP.

Received by (Name): _____ Company _____


Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this ITB has not changed. Bids must be received by the Purchasing Department at the address above, Suite 204, at or before **12:00pm on Thursday, May 20, 2021**. The opening time and date are 3:00pm on Thursday, May 20, 2021.

Questions regarding this solicitation will be accepted until 2:00pm on Friday, May 7, 2021. After that, we will not be able to respond to any inquiries about this project.

If you have questions, please contact Sherry White, Contract Administrator at (770) 305-5314 fax (770) 719-5544 or email at swhite@fayettecountyga.gov.

Sincerely,

A handwritten signature in blue ink, appearing to read "Ted L. Burgess", enclosed within a blue circular scribble.

Ted L. Burgess
Director of Purchasing