

June 3, 2021

**Subject: ITB #1970-B: 100 Pleasant Hill Storm Conveyance Improvement  
Addendum #1**

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced Invitation to Bid. You will need to consider this information when preparing your bid.

- 1. Could you clarify the location, materials and scope of the 2" Sanitary Sewer Force main listed as a Lump Sum item? Does Note 3 on CG101 about bypass pumping refer to this item?**

The Sanitary Sewer Force Main is shown as a dashed "- - SS - -" line approximately 11-feet from the structure at 100 Pleasant Hill and continuing to the labeled approximate location of the septic field shown on sheets V-001, CD-101, and CG-101.

The existing PVC force main is approximately 2-feet deep and shall be confirmed by potholing per Sheet CG-101. The force main is located beneath the proposed river rock lined swale and will require relocation only if determined to be in conflict, per General Sheet Note 6, and may be replaced with appropriate materials for pressurized flow per the current Georgia Department of Public Health Manual for On-Site Sewage Management Systems. All costs to complete the lowering of the force main shall be included in the Lump Sum price.

Sheet CG101 General Sheet Note 3 is removed. A bypass pumping plan will not be required, as it is not anticipated that a waterline bypass will be necessary during waterline relocation work. The Contractor shall coordinate all waterline work with Fayette County Water System.

Received by (Name): \_\_\_\_\_ Company \_\_\_\_\_


Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The due date for this ITB has not changed. **The bid due time and date are 12:00 p.m., Wednesday, June 9, 2021.** Bids must be received by the Purchasing Department at the address above, Suite 204, at or before the bud due date and time.

The deadline for inquiries has passed, so the Purchasing Department will not be able to accept any additional questions after this time.

If you have questions, please contact Natasha Duggan, Contract Administrator at (770) 305-5150, fax (770) 719-5534 or email at [nduggan@fayettecountyga.gov](mailto:nduggan@fayettecountyga.gov).

Sincerely,

A handwritten signature in blue ink, appearing to read "Ted L. Burgess", is written over a large, light blue oval shape.

Ted L. Burgess  
Director of Purchasing