



Purchasing Department

140 Stonewall Avenue West, Ste 204
Fayetteville, GA 30214
Phone: 770-305-5420
www.fayettecountyga.gov

June 16, 2021

Subject: Invitation to Bid #1971-B: Sports Lighting - Addendum #2

Gentlemen/Ladies:

Below, please find additional information for the above referenced Invitation to Bid. You will need to consider this information when preparing your bid.

Questions Received before the Pre-Bid Meeting:

- 1. Do we need to go through the whole pre-approval process with you again, or what do we need to do to get approved to bid on ITB #1971-B?**

There is no pre-approval process for this bid. All requirements are included in the invitation to bid.

- 2. Also, can you please send over any other docs needed for us to quote ITB #1971-B?**

All documents needed are provided in the bid posting on our website at:

https://fayettecountyga.gov/purchasing/bids_and_proposals.htm

- 3. Just to clarify - ITB #1743-B was for fields #21, 24, 25 and ITB #1971-B is for fields #24, 25. Did only field #21 get done the first time around or did this project just go out for re-bid for only fields #24, 25?**

Field 21 was the only field refurbished in ITB #1743-B. ITB #1971-B is for fields #24 and #25.

- 4. Since we had our Electrical Contractor attend the Pre-Bid Meeting for ITB #1743-B on December 4th, 2019, will we be penalized for not attending the pre-bid for ITB #1971-B on 6/10?**

Interested bidders are not required to attend the Pre-Bid Meeting on Thursday, June 10, 2021 at 10am. This is a non-mandatory meeting.

5. Can we get a scaled plan of the fields?

Responders are responsible for measuring fields, poles, fixtures for all fields associated with IFB #1971-B

6. What is the height of the existing poles?

Responders are responsible for measuring mounting heights, field dimensions, and counting light fixtures for all fields associated with IFB #1971-B

7. What is the incoming voltage for the light fixtures?

277/480 – 3 Phase For Lighting, 120/240 is also available at this location for control power

Questions Received During the Pre-Bid Meeting:

8. Where do you want to the key switch to go on the new control panels?

Inside new control panels. There should be one key switch for field 24 and one key switch for field 25.

9. Where are the panels fed from?

Concession area

10. When do you anticipate this work being installed?

December 1, 2021 through March 1, 2022

11. How many bids are allowed?

Only one bid per contractor.

12. Are you wanting to pull new wires to the pole?

Yes new wires should be installed.

13. Do you have anything showing the current wiring?

There are no drawings available

14. Do you want to keep the existing poles?

Yes

15. Do you want to use new conduit?

The contractor shall use existing conduit

16. Do you want to keep old fixtures?

No, the contractor shall remove old fixtures and dispose of them.

Changes and Clarifications:


1. We will need one new switch each for fields 24 and 25. Currently, field 24 has 2 switches.
2. All conductors should have a 25-year warranty.
3. The only thing we are keeping is the poles and conduit.
4. The control panel for field 25 is inside the building
5. The time allowed for questions has expired.

Received by _____ Company _____

Note: Please sign and return this addendum with your submitted bid. Any respondent not returning a signed addendum will still be responsible for compliance with any requirements, specifications, or changes contained in the addendum.

Thank you for your attention to this matter.

Sincerely,



Ted L. Burgess
Director of Purchasing

TLB\tc