



Purchasing Department
140 Stonewall Avenue West, Ste 204
Fayetteville, GA 30214
Phone: 770-305-5420
www.fayettecountyga.gov

September 14, 2021

Subject: RFQ #1996-A: New Storage Building - Addendum #1

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced Request for Quote. You will need to consider this information when preparing your quote.

Questions Received:

- 1. Can we use standard PEMB vinyl backed insulation for the r-13 walls and r-19 roof and the standard PEMB roll up door?**

No, The county will keep the current specifications in order to meet energy code requirements. The county will likely be installing air conditioning at some time in the future.

- 2. Is this a re-bid for the same building with the energy code requirements for a steel building or a new building? If it's a new one I would like to see the other building to see what they actually installed. This is the only building I have had this R5 roll up door and this double spaced insulation requirement I have ever seen. We build several of these a year and this is never a thing. It's always standard vinyl backed insulation walls and ceiling and standard roll up doors.**

This is a re-bid of the same building.

- 3. I am reaching out regarding the Storage Building that you have out for bid currently. In the RFQ, the scope of work is defined as a "Turn Key" metal building. In addition to all the metal building and building accessories specs provided, can you clarify if the contractor is to provide any electrical (power/lighting) or HVAC (heating, cooling, ventilation) as part of the "Turn Key" proposal?**

We will add the electrical and HVAC at another time.

Received by (Name): _____ Company _____

Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals or companies will still be responsible for the requirements of this addendum and the specifications or changes herein.

The due date and time has not changed. The date is 2:00 p.m., Friday, September 17, 2021. You may drop it off in person, there will be a large metal parcel drop box located outside the front door of the Purchasing Department, Suite 204, in the county complex at 140 Stonewall Avenue West, Fayetteville, Georgia. You may also provide your quote and other information via e-mail to tcrumbley@fayettecountyga.gov or fax to (770) 719-5509 on or before the received by date and time.

The time allowed for questions has expired.

Sincerely,



Ted L. Burgess
Director of Purchasing