

March 24, 2022

**Subject: RFQ #2069-A: Flint River Raw Water Pump #1 Repairs  
Addendum #1**

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced Request for Quotes. You will need to consider this information when preparing your quote.

1. **Has the pump been pulled out before?**  
A. Yes, in 2008.
2. **Do you want contractor to install the motor?**  
A. Yes. We will have the motor delivered so that the contractor can install.
3. **Will the County supply the coupling between the motor and pump?**  
A. Yes. The County will provide.
4. **Is it a hollow shaft motor?**  
A. Yes.
5. **Do you have an electrician you want us to use or shall we supply our own?**  
A. Supply Own.
6. **Awarded contractor shall provide 24-hours' notice before starting work.**
7. **Can we stage parts on-site?**  
A. Yes, but contractor is liable for materials.

Received by (Name): \_\_\_\_\_ Company \_\_\_\_\_

Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this RFQ has not changed. **The opening time and date are 3:00 p.m., Thursday, March 31, 2022.** Quotes must be received by the Purchasing Department at the address above, Suite 204, at or before the opening date and time.

The deadline for inquiries has passed, so the Purchasing Department will not be able to accept any additional questions after this time.

If you have questions, please contact Natasha Duggan, Contract Administrator at (770) 305-5150, fax (770) 719-5534 or email at [nduggan@fayettecountyga.gov](mailto:nduggan@fayettecountyga.gov).

Sincerely,

A handwritten signature in blue ink, appearing to read "Ted L. Burgess", is written over a circular blue ink scribble.

Ted L. Burgess  
Director of Purchasing