

March 24, 2022

**Subject: RFQ #2070-A: Crosstown High Service #3 Pump/Motor Repair
Addendum #1**

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced Request for Quotes. You will need to consider this information when preparing your quote.

1. **Does the motor run?**
A. Yes, but it shoots sparks from the top.
2. **Does the motor turn freely?**
A. Yes.
3. **Do you want a steady bushing installed?**
A. Not required.
4. **The shaft grounding ring is internal. Do you want it replaced?**
A. If it requires replacing, then yes.
5. **Attach pump & motor drawing.**
A. See Attachment 1.
6. **Is on/off switch on stand a heater?**
A. No. Local on/off.
7. **What is the weight of the pump?**
A. Unknown.
8. **What is the pump length?**
A. 19FT, 2IN
9. **Drive in system?**
A. The drive is a soft starter.
10. **When was the last time the pump was pulled?**
A. Trying to gather the info, I last show 2005.
11. **When was the motor was added on.**
A. 2005.
12. **Is there any piping underground?**
A. Yes, there is and will discuss with awarded contractor.
13. **Where can we set up a crane?**
A. Will discuss with awarded contractor.
14. **Will you allow the crane operator to come out and review the site?**
A. Yes.

Received by (Name): _____ Company _____

Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this RFQ has not changed. **The opening time and date are 2:00 p.m., Thursday, March 31, 2022.** Quotes must be received by the Purchasing Department at the address above, Suite 204, at or before the opening date and time.

The deadline for inquiries has passed, so the Purchasing Department will not be able to accept any additional questions after this time.

If you have questions, please contact Natasha Duggan, Contract Administrator at (770) 305-5150, fax (770) 719-5534 or email at nduggan@fayettecountyga.gov.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Ted L. Burgess', is written over the typed name and title. The signature is stylized and somewhat cursive.

Ted L. Burgess
Director of Purchasing