

Purchasing Department

140 Stonewall Avenue West, Ste 204 Fayetteville, GA 30214 Phone: 770-305-5420 www.fayettecountyga.gov

May 13, 2022

Subject: RFQ #2119-A: Lake Kedron Intake House Repairs

Addendum #1

Gentlemen/Ladies:

changes herein.

Below, please find responses to questions, clarification, or additional information for the above referenced Request for Quotes. You will need to consider this information when preparing your quote.

- Do you want the metal siding attached directly to the studs with existing plywood removed?
 Do you prefer metal siding placed over existing plywood?
 Attach it directly over the existing plywood and through plywood into studs.
- 2. Interior Painting. Do you want all interior exposed surfaces painted including studs, rafters, trusses, and inside of siding and roof?

 Yes.
- 3. Can we close off incoming water to the intake structure to do work inside structure? What would be the maximum time to have the water flow off?

 Yes it can be closed and up the max would be 3-days (however as long as the spillway is running then the valve may remained closed).
- 4. Do you have a brand/model of the 10" valve that needs the handwheel replaced? No.

| Receive | ed by (Name): | Company |
|---------|---------------|---|
| | | yette County Purchasing Department or if it luals, companies or other organizations will |

still be responsible for the requirements of this addendum and the specifications or

The opening date for this RFQ has not changed. The opening time and date are 3:00 p.m., Friday, May 20, 2022. Quotes must be received by the Purchasing Department at the address above, Suite 204, at or before the opening date and time.

The deadline for inquiries has passed, so the Purchasing Department will not be able to accept any additional questions after this time.

If you have questions, please contact Natasha Duggan, Contract Administrator at (770) 305-5150, fax (770) 719-5534 or email at nduggan@fayettecountyga.gov.

Sincerely,

Ted L. Burgess

Director of Purchasing