

December 13, 2022

**Subject: Request for Quotes #2149-A Fountain Repair @ Justice Center  
Addendum #1**

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced Request for Quotes (RFQ). You will need to consider this information when preparing your quote.

**1. Any color on the waterproofing acceptable?**

Yes, any color may be quoted.

**2. Do we have access to electricity?**

Yes, access to electricity is available.

**3. Do you want to replace the pump lines?**

Yes, all pump lines shall be replaced.

**4. Do you know if there is a crack inside the fountain?**

No, we are not aware of any cracks.

**5. Is it okay to come back at a different time to view the fountain area?**

Yes, the fountain is in a public location.

**6. Do you have existing specifications on the existing tile?**

No, no additional information is available.

**7. Are the 2 pumps to be replaced the same kind?**

Yes, both pumps shall be replaced in kind.

**8. Do you have the model numbers of the pumps?**

No, the only legible information on the pump is *Alpine Cyclone Pond Pump*.

**9. Is any work needed on the stone surfaces?**

No.

**10. Will this project require a permit?**

Building safety requires a licensed plumber to complete the fountain work.

**11. Is there a date we must start work?**

Please see term and condition #14 and provide this information on the pricing sheet.

**12. What are the specifications for the existing water lines?**

The existing water line is made of hard rubber.

**13. Do you have any diagrams showing the water line layout inside the fountain?**

Due to the age of the fountain, no layouts are available.

**14. What GPH (Gallons per hour) is required for the alpine cyclone pond pump?**

The minimum of 2,600 gallons per hour which is the speed of the current pump.

**COMPANY NAME:** \_\_\_\_\_

Received by (Name): \_\_\_\_\_ Company \_\_\_\_\_

Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this RFQ has not changed. **The opening time and date are 3:00p.m., Thursday, December 15, 2022.** Quotes must be received by the Purchasing Department at the address above, Suite 204, at or before the opening date and time.

The time for questions regarding this solicitation has passed. We will not be able to respond to any inquiries about this project.

If you have questions, please contact Sherry White, Contract Administrator at (770) 305-5314 fax (770) 719-5544 or email at [swhite@fayettecountyga.gov](mailto:swhite@fayettecountyga.gov).

Sincerely,



Ted L. Burgess  
Director of Purchasing