

August 16, 2022

**Subject: RFQ #2153-A: Fire Station 7 HVAC Replacement
Addendum #1**

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced Request for Quotes. You will need to consider this information when preparing your quote.

- 1. Do you want the thermostat replaced?**
Yes. Replace it with a like product.
- 2. Is there any preference on a thermostat?**
No.
- 3. The current unit is a single phase. A 15 SEER is not offered in a 3-phase.**
Replacement unit shall be a 3-phase, 230 Volt, 14 SEER minimum.
- 4. Do you want a specific model like Carrier or Trane as a replacement or just something comparable?**
Trane or equivalent.
- 5. Are you looking to upsize the unit or keep it the same specs as the existing?**
No. Keep it the same.

Received by (Name): _____ Company _____


Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this RFQ has not changed. **The opening time and date are 3:00 p.m., Friday, August 19, 2022.** Quotes must be received by the Purchasing Department at the address above, Suite 204, at or before the opening date and time.

The deadline for inquiries has passed, so the Purchasing Department will not be able to accept any additional questions after this time.

If you have questions, please contact Natasha Duggan, Contract Administrator at (770) 305-5150, fax (770) 719-5534 or email at nduggan@fayettecountyga.gov.

Sincerely,

A handwritten signature in blue ink, appearing to read "Ted L. Burgess", with a large, sweeping flourish that loops back over the signature.

Ted L. Burgess
Director of Purchasing