

October 20, 2022

**Subject: RFQ #2179-A: Water System Admin Bathroom Renovation
Addendum #1**

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced Request for Quotes. You will need to consider this information when preparing your quote.

1. Do the drawings submitted by the awarded vendor need to be stamped by an engineer or an architect?

An architect is not required to stamp the plans. The plans do need to be to scale and have all MEP's included in the scope to include before and after.

2. Do you want the new wall tile installed to the same height as the current wall tile?

New tile shall be 48-inches in height.

3. Is the water fountain between the two bathrooms part of the project?

No.

4. Do you want the ceiling tile replaced?

No.

5. Do we need to replace the exhaust fans?

No.

6. Is any electrical work included?

No.

7. Plumbing in the bathroom may need to be removed and will be noisy. How do we handle so the office is not disturbed?

This work can be scheduled to occur outside of office hours. One week notice is required to schedule the work.

8. How will crews access the work area?

Crews shall access the building via the south door (door facing the dumpsters).

9. Can we use the existing dumpster?

No. Contractor shall provide their own dumpster. The existing dumpster on-site is for Water System use only.

Received by (Name): _____ Company _____


Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this RFQ has not changed. **The opening time and date are 2:00 p.m., Thursday, October 27, 2022.** Quotes must be received by the Purchasing Department at the address above, Suite 204, at or before the opening date and time.

Questions regarding this solicitation will be accepted until 2:00 p.m., Friday, October 21, 2022. After that, we will not be able to respond to any inquiries about this project.

If you have questions, please contact Natasha Duggan, Contract Administrator at (770) 305-5150, fax (770) 719-5534 or email at nduggan@fayettecountyga.gov.

Sincerely,



Ted L. Burgess
Director of Purchasing