

October 10, 2022

**Subject: RFQ #2183-A: Fire Station 2 Fuel Tank Installation  
Addendum #1**

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced Request for Quotes. You will need to consider this information when preparing your quote.

- 1. Does the county have a preference on the type of tank monitoring system? Or do we give our recommendation for what is needed to monitor tank level, leak detection, and the overfill alarm?**

Provide a Clock style gauge with an alarm and a leak indicator, such as a Morrison FIG 724 or Krueger type K or equivalent.

- 2. Instead of installing stairs for the tank to be filled from the top can we suggest a remote fill location, with spill containment, that will allow the tank to be filled from ground level?**

No.


- 3. How will the County authorize/activate the fuel dispenser?**

The pump will be lockable with a padlock.

- 4. Depending on the answer to #3 does the County want a basic dispenser that just shows total gallons dispensed and is lockable by a padlock to try and deter theft?**

Yes.

5. Please provide pictures of existing electrical panel to see if it will suffice for the new proposed fueling equipment.



6. What is the distance from panel to proposed tank installation area?

60ft. There is a power source close for the pump on a dedicated breaker. The air compressor is no longer in use and contractor will be able to use that circuit breaker if they choose to.

Received by (Name): \_\_\_\_\_ Company \_\_\_\_\_

Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this RFQ has not changed. **The opening time and date are 2:00 p.m., Tuesday, October 18, 2022.** Quotes must be received by the Purchasing Department at the address above, Suite 204, at or before the opening date and time.

**Questions regarding this solicitation will be accepted until 2:00 p.m., Tuesday, October 11, 2022.** After that, we will not be able to respond to any inquiries about this project.

If you have questions, please contact Natasha Duggan, Contract Administrator at (770) 305-5150, fax (770) 719-5534 or email at [nduggan@fayettecountyga.gov](mailto:nduggan@fayettecountyga.gov).

Sincerely,

Ted L. Burgess  
Director of Purchasing