

December 22, 2022

**Subject: Request for Quotes #2203-A Mini-Split for IT  
Addendum #2**

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced Request for Quotes (RFQ). You will need to consider this information when preparing your quote.

- 1. Should the contractor demo the Liebert system before or after the new installation?**  
The new unit shall be placed on the wall behind the Liebert System so you will have to demo the existing unit before installation.
- 2. Where do you want the new system installed?**  
The new unit shall be installed on the wall behind the existing Liebert System.
- 3. Is the existing unit on emergency power?**  
Yes.
- 4. Where is the emergency power panel located?**  
The emergency panel is currently located on the first floor of the building.
- 5. Does the electrical power currently run overhead to the Liebert System or underground?**  
Currently the power is supplied to the Liebert system from the ceiling.
- 6. Where is the existing line set for the Liebert system?**  
The current line set runs overhead into the ceiling.
- 7. Is the contractor responsible for the ceiling and floor replacements when the Liebert system is demolished?**  
The contractor shall replace in kind the ceiling and flooring surrounding the new unit.
- 8. Will the contractor use the County's roofer or supply their own? If the County's, please provide a name and number?**  
The contractor shall use their own licensed roofer.
- 9. What are the recent heat load calculation for the server room?**  
No heat load calculations have been recorded.
- 10. What is the amount of humidity needed in the server room?**  
The server room requires 40-60% humidity.

**11. Once the mini-split drops the humidity in the room, is a humidifier needed?**

If a humidifier is required, the county will provide one.

**12. Please verify if an engineer stamped design is required for wind uplift?**

Since the current unit is being replaced with a smaller unit this requirement is no longer needed.

**COMPANY NAME:** \_\_\_\_\_

Received by (Name): \_\_\_\_\_ Company \_\_\_\_\_


Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this RFQ has changed. **The opening time and date are 3:00p.m., Wednesday, December 28, 2022.** Quotes must be received by the Purchasing Department at the address above, Suite 204, at or before the opening date and time.

The time for questions regarding this solicitation has passed. We will not be able to respond to any inquiries about this project.

If you have questions, please contact Sherry White, Contract Administrator at (770) 305-5314 fax (770) 719-5544 or email at [swhite@fayettecountyga.gov](mailto:swhite@fayettecountyga.gov).

Sincerely,



Ted L. Burgess  
Director of Purchasing