

January 19, 2023

**Subject: RFQ #2212-A: Survey for Sidewalk Repairs at Kenwood Park
Addendum #1**

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced Request for Quotes. You will need to consider this information when preparing your quote.

1. This is an RFQ for survey only and not the repair work that will follow in another bid. Is that correct?

This RFQ is for a survey only.

2. In the PDF, you are looking for a plat showing the locations of where the sidewalk has uplifted and created trip hazards. How much uplift is considered a hazard?

County is looking for a plat with any sidewalk trip hazard (i.e. vertical change in height) in accordance with ADA regulation which is $\frac{1}{4}$ ".

3. Or is the County looking for a plat with spot grades at every expansion joint and will determine what needs to be replaced?

County is looking for a plat with any sidewalk trip hazard (i.e. vertical change in height) in accordance with ADA regulation which is $\frac{1}{4}$ ". The County will determine what needs to be replaced and in what order it needs replacing once survey is complete and plat has been submitted.

4. What are deliverables? A paper plat only or any electronic files too?

Both paper and electronic files

5. If we deliver the bid by email, how should the email be addressed and formatted to keep it 'sealed'?

This is not a sealed bid. Email your quote to purchasinggroup@fayettecountyga.gov before the deadline listed below.

6. Under "scope of work", under survey, #3 is asking for detailed information for "cost of correction." Is this a RFQ for survey or and RFQ for repairs? To clarify, this is not information that must be submitted on January 25th, but is the information that the awarded vendor for the survey must supply if approved to do the survey? Is that correct?

This RFQ is for a survey only. The cost of correction is just a proposed cost for budgetary purposes only which will provided by the awarded vendor.

7. Does the awarded vendor have to be a licensed surveyor or design professional?

No. However, include with your quote a list of three (3) jobs that your company has done which were the same or similar in scope.

Received by (Name): _____ Company _____

Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this RFQ has not changed. **The opening time and date are 2:00 p.m., Wednesday, January 25, 2023.** Quotes must be received by the Purchasing Department at the address above, Suite 204, at or before the opening date and time.

The deadline for inquiries has passed, so the Purchasing Department will not be able to accept any additional questions after this time.

If you have questions, please contact Natasha Duggan, Contract Administrator at (770) 305-5150, fax (770) 719-5534 or email at nduggan@fayettecountyga.gov.

Sincerely,



Ted L. Burgess
Director of Purchasing