

February 16, 2023

**Subject: RFQ #2221-A: Lakeview Lane Trenchless Rehabilitation
Addendum #1**

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced Request for Quotes. You will need to consider this information when preparing your quote.

1. Is there going to be a bid bond required for this quote?

There is no bid bond requirement in the RFQ.

2. Would shotcrete be considered an acceptable alternative lining method instead of the SIPP for this project

The existing pipe shall be rehabilitated by slip lining with either smooth steel or High-Density Polyethylene (HDPE) type liners only. Sprayed-In-Place-Pipe (SIPP) is not an acceptable method for this project.

Received by (Name): _____ Company _____


Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this RFQ has not changed. **The opening time and date are 3:00 p.m., Thursday, February 23, 2023.** Quotes must be received by the Purchasing Department at the address above, Suite 204, at or before the opening date and time.

The deadline for inquiries has passed, so the Purchasing Department will not be able to accept any additional questions after this time.

If you have questions, please contact Natasha Duggan, Contract Administrator at (770) 305-5150, fax (770) 719-5534 or email at nduggan@fayettecountyga.gov.

Sincerely,

A handwritten signature in blue ink, appearing to read "Ted L. Burgess", enclosed within a large, loopy blue oval flourish.

Ted L. Burgess
Director of Purchasing