

September 11, 2023

**Subject: ITB #2309-B: CAMP CREEK PATH PHASE I
Addendum #1**

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced Invitation to Bid (ITB). You will need to consider this information when preparing your quote.

1. Who marked the trees along the path with the pink x?

Fayette County staff marked some trees with a pink X during preliminary design work, but the markings have no significance for the bid.

Quotes should be based on the project specifications to clear and grub “all vegetation within ten (10) feet of the path’s assumed centerline (20-ft total)”. This includes any tree whose trunk-at-breast-height is touching or within a 10-ft centerline offset.

2. Are we to assume the center line for the current path for the project?

Yes, the centerline for the project shall be assumed from the existing path. Fayette County owns the land on both sides of the path.

3. Who will establish the property line of the Home Owners Association?

The Contractor is responsible for retaining a Georgia-registered licensed surveyor (RLS) to locate and establish the property line. See the Project Scope Item 1 for more information.

4. Once we grad outside of the asphalt path, how would you like to finish the path edges?

Grading and finishing along the path edges shall be in accordance with the Typical Section provided in the bid documents. This includes a 2-ft GAB shoulder within minimum depth of 6 inches and an additional 2-ft earth shoulder. The shoulder areas plus the 12-ft path result in a 20-ft project work area. Positive drainage, per the specifications, shall be provided across the area.

Mulch may be used over disturbed areas as final stabilization (see Project Scope Item 14).

5. Will public access to the path be allowed during construction?

The Contractor may allow or prohibit public access to the path during construction, as appropriate for public safety. Regardless of method followed, all costs associated with either accommodating or restricting public access shall be borne by the Contractor. This includes, but is not limited to barricades, signs, aggregate surface course (ASC), etc.

Public use and access to Gristmill Drive shall be always maintained.

6. Can the contractor dump waste from the project at the local transfer station?

Yes, the transfer station is a public facility and may be used by the Contractor to dispose of waste. The current fee is \$43.00 a ton, plus fees. All costs associate with waste disposal (loading, hauling, fees, etc.) shall be paid by the Contractor as part of their bid.

Received by (Name): _____ Company _____


Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this ITB has not changed. **The opening time and date are 3:00p.m., Friday, September 15, 2023.** Quotes must be received by the Purchasing Department at the address above, Suite 204, at or before the opening date and time.

The time for questions has passed, we will not be able to respond to any inquiries about this project.

If you have questions, please contact Sherry White, Contract Administrator at 770-305-5314 or by email swhite@fayettecountyga.gov or fax to (770) 719-5544

Sincerely,



Ted L. Burgess
Director of Purchasing