

September 29, 2023

**Subject: RFQ #2323-A: Roof & Gutter Repair @ Station 11
Addendum #1**

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced RFQ. You will need to consider this information when preparing your quote.

- 1. Do you have you have the Architectural plans for the fire station 11?**
No. The building was built in 1988 and we do not have any original plans.
- 2. Are you accept any other roofing manufacturers? That's equal to Carlisle. (Firestone or Dur-last)**
No. The contracts request the use of Carlisle roofing material only.
- 3. Are we put crickets in between scuppers?**
Yes. The water must be directed to the scuppers.

Received by (Name): _____ Company _____


Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this RFQ has not changed. **The opening time and date are 3:00p.m., Thursday, October 5, 2023.** Quotes must be received by the Purchasing Department at the address above, Suite 204, at or before the opening date and time.

The deadline for inquiries has passed, so the Purchasing Department will not be able to accept any additional questions after this time.

If you have questions, please contact Sherry White, Contract Administrator at (770) 305-5314, fax (770) 719-5544 or email at swhite@fayettedcountyga.gov .

Sincerely,



Ted L. Burgess
Director of Purchasing