

January 2, 2024

**Subject: ITB 2348-B: Downing Court Culvert Replacement  
Addendum #1**

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced Invitation to Bid. You will need to consider this information when preparing your bid.

**1. Do you have a budget for this project?**

The County does not release the budget for active projects. We request you bid the project based on the Scope of Work.

**2. Can the road be closed to complete the work?**

No. As stated on the plans and in the specifications, at least one 12-foot travel lane must remain open for traffic at all times.

**3. Can we use precast headwalls in lieu of the GDOT poured in place headwalls?**

Yes. Precast or Poured in Place is acceptable.

**4. What is the thickness of the existing asphalt pavement that needs to be removed to replace the culvert?**

The thickness of existing asphalt pavement to be removed is unknown.

**5. What thickness of 9.5 MM superpave and 19 MM superpave must be installed?**

Refer to the Fayette County Typical Road Cross Section in detail C4 on Sheet C-501 of the plans for a "local" road.

6. Has the gas company been notified that their gas line needs to be relocated since the gas (utility) companies do not want anyone else to relocate their lines? Without prior notification, it may take months before they may be able to perform the relocation.

All utilities have been notified of the project. As stated in Section 105.06 of the specifications it is the Contractor's responsibility to plan with each utility owner a schedule of operations for adjustment and/or relocation.

Received by (Name): \_\_\_\_\_ Company \_\_\_\_\_

Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this ITB has not changed. **The opening time and date are 2:00 p.m., January 5, 2024.** Bids must be received by the Purchasing Department at the address above, Suite 204, at or before the opening date and time.

The deadline for inquiries has passed, so the Purchasing Department will not be able to accept any additional questions after this time.

If you have questions, please contact Natasha Duggan, Contract Administrator at (770) 305-5150, fax (770) 719-5534 or email at [nduggan@fayettecountyga.gov](mailto:nduggan@fayettecountyga.gov).

Sincerely,



Ted L. Burgess  
Chief Procurement Officer