

September 19, 2024

**Subject: ITB #2428-B Fayette County Resurfacing FY2022 - Construction
Addendum #1**

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced ITB. You will need to consider this information when preparing your bid.

- 1. What is the limited duration or expected duration of the project?** The ITB has been updated to include the bid advertisement which states the successful bidder will have up to 210 consecutive calendar days to complete the work upon receipt of a NTP to construction from Fayette County. Refer also to the General Notes for other time/schedule requirements.
- 2. When does the County anticipate giving the notice to proceed for the project?** Request to Award is anticipated to be included on the October 24, 2024, BOC Meeting agenda. Notice to Proceed is dependent on the timeframe the contractor provides required documents back to the County.
- 3. Will the County allow the contractor to wet cure the Cement Stabilized Base Course in lieu of the 89 Surface Treatment Layer?** No, the contractor shall adhere to the bituminous prime curing and surface treatment requirements for the Cement Stabilized Base Course (CSRB) as stipulated in the Specifications and or Special Provision 315 as applicable.
- 4. Will the County provide and pay for the testing of the Cement Stabilized Base Course?** No, the County will not provide or pay separately for testing of the CSRB. It is the Contractor's responsibility to provide testing of CSRB and related constituents as it is being mixed and placed to ensure conformance with Section 315. The Georgia Department of Transportation has agreed to provide limited materials acceptance testing of completed work only.
- 5. Is a material transfer vehicle (MTV) or Shuttle Buggy required for placement of the 19mm and 112.5mm asphalt?** No, material transfer vehicles (MTV's) or shuttle buggies are not required for placement of the 19mm and 12.5mm asphalt mixes.

Received by (Name): _____ Company _____


Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this ITB has not changed. **The opening time and date are 3:00 p.m., Friday, September 27, 2024.** Bids must be received by the Purchasing Department at the address above, Suite 204, at or before the opening date and time.

The deadline for inquiries has passed, so the Purchasing Department will not be able to accept any additional questions after this time.

If you have questions, please contact Sherry White, Contract Administrator at (770) 305-5314, fax (770) 719-5544 or email at swhite@fayettecountyga.gov .

Sincerely,



Ted L. Burgess
Chief Procurement Officer

TLB/sw