

October 15, 2024

**Subject: RFQ #2476-A Senior Center HVAC Replacement
Addendum #1**

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced RFQ. You will need to consider this information when preparing your quotes.

- 1. What refrigerant is acceptable for the new equipment? R34 does not exist. At the meeting I heard R32, is this correct?**
Please use R32.
- 2. What does the 4581.25/4581.25 conditioner mean? I assume condenser. Please inform me when you get a moment. Is this for two systems or just one condenser?**
This is for the condenser only, 7.5 ton.
- 3. In reference to the multi-position coil. It has in parentheses (2) at the end of the sentence.....does that stand for two coils and just one coil for the quote?**
If a single replacement coil can be found, it can be used. If not - 2 separate coils equaling 7.5 tons for a single 7.5 ton condenser should be used.

Received by (Name): _____ Company _____


Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this RFQ has not changed. Quotes must be received by the Purchasing Department at the address above, Suite 204, at or before the opening date and time.

The deadline for inquiries has passed, so the Purchasing Department will not be able to accept any additional questions after this time.

If you have questions, please contact Sherry White, Contract Administrator at (770) 305-5314, fax (770) 719-5544 or email at swhite@fayettecountyga.gov .

Sincerely,



Ted L. Burgess
Chief Procurement Officer