

October 22, 2024

**Subject: ITB #2488-B: FY25 Resurfacing Project
Addendum #2**

Gentlemen/Ladies:

Below, please find responses to questions, clarification, or additional information for the above referenced ITB. You will need to consider this information when preparing your bid.

- 1. Regarding manhole adjustments, if needed, may riser rings be used?** Unincorporated Fayette County has no manholes in the roadway.
- 2. Will the county please specify which roads crack seal is desired and in what order of operations?** Crack sealing on all roads except Flat Creek Trail.
- 3. Would the County consider substituting Liquid Anti-Strip Additive for Hydrated Lime per the attached GDOT Bulletin?** Not for this contract, but Fayette County will research Liquid Anti-Strip Additives as a possibility for future contracts.
- 4. There is only 500 SY estimated of milling on Milam Rd. However, the estimated length is 1.08 miles on the provided list. What is the expected scope on this road?** Limited milling of tie-in joints and edge mill where there is curb and gutter.
- 5. Is the goal to edge mill these streets or full width mill?** Edge mill Nix Ct & Point Ridge Court. Full Mill Flat Creek Trail. All other roads mill out tie-in joints.


Received by (Name): _____ Company _____

Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, responding individuals, companies or other organizations will still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this ITB has not changed. **The opening time and date are 3:00p.m, Thursday, October 31, 2024.** Bids must be received by the Purchasing Department at the address above, Suite 204, at or before the opening date and time.

The deadline for inquiries has passed, so the Purchasing Department will not be able to accept any additional questions after this time. If you have questions, please contact Sherry White, Contract Administrator at (770) 305-5314, fax (770) 719-5544 or email at swhite@fayettecountyga.gov.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Ted L. Burgess', enclosed within a blue oval scribble.

Ted L. Burgess
Chief Procurement Officer

TLB/sw