



# Fayette COUNTY

"WHERE QUALITY  
IS A LIFESTYLE"

**PURCHASING DEPARTMENT**  
140 STONEWALL AVENUE WEST, STE 204  
FAYETTEVILLE, GEORGIA 30214  
PHONE: 770-305-5420  
www.fayettecountyga.gov

June 5, 2015

**Subject: Invitation for Bids #985-B Water System Chemicals – Addendum #3**

Ladies and Gentlemen:

Included herein is additional information and clarification for the above referenced invitation for bids. Please consider all of the information when preparing your bid. Please acknowledge receipt of this addendum by signing in the space provided and returning it with your bid.

**1. Can you provide a spec sheet for the Polymer?**

Attached please review the Certificate of Analysis from a current order of the Polymer Clarifloc; A210P.

Received by \_\_\_\_\_ Company \_\_\_\_\_

**Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, all responders shall still be responsible for the requirements of this addendum and the specifications or changes herein.**

The opening date for this invitation for bids has not changed. The opening date will be 3:00pm, Thursday, June 18, 2015. Bids must be received in the Purchasing Department at the address above in Suite 204 on or before the opening date and time.

Thank you for your attention to this matter.

Sincerely,

Ted L. Burgess  
Director of Purchasing

Attachment

# CERTIFICATE OF ANALYSIS

CUSTOMER NAME :  
FAYETTE COUNTY WATER

NAME :      CLARIFLOC A-210P				
DATE :    04/02/2015				
AMOUNT :    450 LB			QUALITY CONTROL	QC
	UNIT	SPECIFICATION	BATCH NUMBER RA40/1847M	TEST
BULK BROOKFIELD VISCOSITY	cps	500 - 2000	1127	1010 A
NON VOLATILE SOLIDS	%	34.0 - 41.0	36.7	1050 A
UL BROOKFIELD VISCOSITY	cps	7.50 - 9.30	7.64	1019 A
RESIDUAL MONOMER	ppm	0 - 499	0	1001 A
			Date :    04/02/2015	

If the # symbol appears in the QC-TEST column, then the data on that line is given for information only, and does not constitute a specification.